

**Δ Table 130.7(C)(7) Rubber Insulating Equipment, Maximum Test Intervals**

<b>Rubber Insulating Equipment</b>	<b>When to Test</b>
Blankets	Before first issue; every 12 months thereafter*
Covers	If insulating value is suspect
Gloves	Before first issue; every 6 months thereafter*
Line hose	If insulating value is suspect
Sleeves	Before first issue; every 12 months thereafter*

\*New insulating equipment is not permitted to be placed into service unless it has been electrically tested within the previous 12 months. Insulating equipment that has been issued for service is not new and is required to be retested in accordance with the intervals in this table.